

Vly High Service Area Expansion Study

Public Information Meeting March 27, 2018

Introductions






Latham Water District:
John Frazer, Superintendent
Dan Seaver, Water Engineer

O'Brien & Gere: Rick Gell, Project Manager Brian Edwards, Engineer





Purpose

- Latham Water has received customer requests to improve pressure in the elevated area on the western side of Town
- Present Latham Water's evaluation of how to improve pressures through the expansion of the Vly High Service Area
- Describe origination of the Vly High Service Area
- Outline what Latham Water will be expecting from you
- Garner input from the community

Latham Water System


Three Sources of Raw Water

- Stony Creek Reservoir
- Mohawk River
- Wells Along the Mohawk River

Sources Combined at the Mohawk View Water Treatment Plant

Water is distributed through more than 430 miles of water mains






Drinking Water for Colonie



Drinking Water Treatment & Delivery

WATER TREATMENT PLANT SURFACE WATER SUPPLY





Water System Hydraulics

Hydraulic Considerations

- Hydraulic Grade Line
- System Flow
- Hydrant Flow Required
- Static Head or Pressure
- Head or Pressure Loss

HYDRAULIC GRADE LINE




Figure 7.2a No Flow Condition




Figure 7.2.b Low Flow Condition





Figure 7.2c High Demand Condition



Hydraulics Basics – Static Head



Static Head at water surface = Opsi

Static Head at base of tank = 39psi (500ft. – 410ft.) x 0.433psi/ft.

Static Head at House = 87psi (500ft. – 300ft.) x 0.433psi/ft.

The water level in Latham Water's tanks varies between about 470ft. and 500ft. above sea level depending on time of day and time of year.



The higher you move up the hill, the lower the pressure will be at the house.



The further down the hill you move, the higher the pressure will be at the house.




Vly High Topography



Ground Elev. Above 400 ft




Map of
Current
Vly High
Service Area





Map of Current Pressures



Parcels within red that are not highlighted in yellow may have pressures below 35 psi.

Parcels Served





Current Regulatory Requirements/Standards

2012 Recommended Standards of Waterworks ("Ten State Standards")

8.2.1 Pressure: All water mains, including those not designed to provide fire protection, shall be sized after a hydraulic analysis based on flow demands and pressure requirements. The system shall be designed to maintain a minimum pressure of 20 psi (140 kPa) at ground level at all points in the distribution system under all conditions of flow. The normal working pressure in the distribution system shall be at least 35 psi (240 kPa) and should be approximately 60 to 80 psi (410 - 550 kPa) and not less than 35 psi (240 kPa).

New York State Part 5 Drinking Water Supply


5-1.27 Adequacy of Distribution System: The public water system shall be maintained and operated by the supplier of water to assure a minimum working pressure of 20 pounds per square inch at ground level at all points in the distribution system.

New York State Building Code

604.8 Water pressure-reducing valve or regulator. Where water pressure within a building exceeds 80 psi (553kPa) static, an approved water pressure reducing valve conforming to ASSE 1003 or CSA B356 with strainer shall be installed...



Map of Proposed Expanded Vly High Service Area



Parcels Served



Parcels potentially served in future





Map of
Projected
Normal
Operating
Pressures in
Proposed High
Pressure Zone




High Pressure
Zone Parcels in
green areas would
have pressures
greater than 80 psi
and may require
PRVs.

Water mains (Elev<370 ft.) which may have pressures greater than 100 psi.



Latham Water
Improvements
Needed to
expand Vly High
Service Area






FIRE FLOWS

Latham Water has a goal of supplying at least 750 gpm at 20 psi residual, which is sufficient to meet the ISO recommended minimum fire flows for single family residences.



Map of projected available fire flows



Design Fire Flow


<500 gpm

500-750 gpm

>750 gpm



Customer Needed Improvements




Parcels Highlighted in Red have pressures potentially above 80 psi (PRVs required)

Latham Water will purchase and turn over the PRVs to Customer

Customer would install and maintain



Service Connection Requirements








Other Potential Customer Impacts



Increasing the water pressure could result in new leaks in deteriorating water mains and service connections, and interior premise plumbing. Latham Water maintains on-call crews to repair the water mains breaks and the utility owned portion of the service lines. Customers own and are responsible for the portion of the service line and premise plumbing on their property.







Summary & Conclusions

Expansion of the Vly High Service Area is a viable alternative to installation and maintenance of individual booster pumps by customers

Proposed service area boundaries would position Latham Water to deliver water to customers throughout the western portion of the District at pressures of 35 PSI or more under normal operating conditions

Expansion of the Vly High Service Area will maintain or improve fire flows in the area

Approximately 334 homeowners would need to install PRVs on their service lines







Latham Water garners input from the community



Engineering report outlining proposed improvements and service area is finalized



Project advances through the capital planning and administrative approval process. A phased implementation plan is likely.



Once a phase is selected and approved, homeowners will be notified of the implementation plan and schedule.



PRVs would be turned over to homeowners for installation by owner.



Latham Water would complete the needed District improvements and complete the changeover.



Next Steps



Questions? Thank you!